

# IEC 61850 Certificate - IEC 61850 Certificate #6306

## K-IED ABK100

03/29/2023 04:44 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200185_Kyongbo_IED_K-IED ABK100_Server_Ed2_KERI_r1.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: CF5E0DB6BDB87D044265153351C81C E4272188D670C9DB476E1525B8B05D AA2A
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Kyongbo Electric Co, Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	K-IED ABK100	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	MCU version: 2.00/DSP version: 1.00	<b>Serial Number:</b>	
<b>SW Version:</b>	COMM version: 2.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/29/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b> Protection IED (K-IED ABK100)			

### History

#1 - 03/29/2023 04:55 PM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

### Files

23TC200185\_Kyongbo\_IED\_K-IED ABK100\_Server\_Ed2\_KERI\_r1.pdf 503 KB

03/29/2023

Herbert Falk