

# IEC 61850 Certificate - IEC 61850 Certificate #6309

## MiCOM P40 Agile

03/30/2023 01:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	50745.6741.802_GE_P741_V91B_Edition2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: F270CA74DC4F8833DC97B2136DBFA A30E9788AE8E8A369E0C90F53284862 67D0
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Renewable Energy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Building, Harry Kerr Drive Stafford ST16 1WT United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	MiCOM P40 Agile	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	M	<b>Serial Number:</b>	
<b>SW Version:</b>	91B	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Differential, Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/30/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Grid Automation Laboratories (B)		
<b>Description</b> Distributed Busbar Differential Protection Relay			

### Files

50745.6741.802_GE_P741_V91B_Edition2_Certificate.pdf	208 KB	03/30/2023	Herbert Falk
--	--------	------------	--------------