

# IEC 61850 Certificate - IEC 61850 Certificate #6311

## PSL 603U

04/02/2023 12:12 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-D 002427 0009_SAC_PSL603U_IEC61850Ed2.0_Server_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 0737707EAA835A6F9B1813CFEDB805 8802C2A4D6B8BC8CF2F81FB6785474 1A26
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GUODIAN NANJING AUTOMATION CO., LTD. /NANJING SAC POWER GRID AUTOMATION CO., LTD.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No.39, Shuige Road, Jiangning Development Zone, 211153, Nanjing, PEOPLE'S REPUBLIC OF CHINA	<b>Umbrella Organization:</b>	
<b>Product:</b>	PSL 603U	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	L1.00-K	<b>Serial Number:</b>	
<b>SW Version:</b>	6.01.00.01	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/02/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Description</b>			
Line Protection			

### Files

23-D 002427 0009_SAC_PSL603U_IEC61850Ed2.0_Server_Certificate.pdf	1.6 MB	04/02/2023	Herbert Falk
---	--------	------------	--------------