IEC 61850 Certificate - IEC 61850 Certificate #6311

PSL 603U

04/02/2023 12:12 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	23-D 002427 0009_SAC_PSL603U_IEC61850Ed2.0_Server_Certificate.pdf
61850 Tested Aspects:	Server	**Certificate Hash:**	SHA256: 0737707EAA835A6F9B1813CFEDB8058802C2A4D6B8BC8CF2F81FB67854741A26
Company:	GUODIAN NANJING AUTOMATION CO., LTD. /NANJING SAC POWER GRID AUTOMATION CO., LTD.	**Vendor Artifact File Name:**	
Address:	No.39, Shuige Road, Jiangning Development Zone, 211153, Nanjing, PEOPLE'S REPUBLIC OF CHINA	**Vendor Artifact Hash:**	
Product:	PSL 603U	**Umbrella Organization:**	
HW Version:	L1.00-K	**Optional Reservation Test:**	Yes
SW Version:	6.01.00.01	**Serial Number:**	
Key Words:	Relay	**Publisher Legacy Variants:**	-
Test Procedure Version:	2.0.6	**Publisher Preferred Rates:**	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Herbert Falk	**Subscriber Legacy Variants:**	-
Approval Date:	04/02/2023	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	-
Current Test Lab Name:	TUV SUD China Ltd (A)	**Product Variants:**	
Test Document:	Edition 2 Server Test Procedures version 2.0.6		

Description

Line Protection

Files

23-D 002427 0009_SAC_PSL603U_IEC61850Ed2.0_Server_Certificate.pdf	1.96 MB	04/02/2023	Herbert Falk