

# IEC 61850 Certificate - IEC 61850 Certificate #6313

## Protection IED (PAC-XF100)

04/09/2023 07:51 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200211_PNCTech_IED_PAC-XF100_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: B8B4DD8235D87753F4087769611F016 18D27FCCEBE14C1562E8BB2DEBB06 BE70
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	PNC Tech Co, Ltd	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	62, Jeonpa-ro, 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, 14042, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	Protection IED (PAC-XF100)	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	MPU version: 1.00\DSP version: 1.00	<b>Serial Number:</b>	
<b>SW Version:</b>	IEC 61850 version: 1.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/09/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### Files

23TC200211_PNCTech_IED_PAC-XF100_Server_Ed2_KERI.pdf	496 KB	04/09/2023	Herbert Falk
--	--------	------------	--------------