

IEC 61850 Certificate - IEC 61850 Certificate #6315

SA IMD DW-IPC-A-10000

04/11/2023 07:45 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Device Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-014054-04-2_Dowoo_SA IMD_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: FC95B6CD8FF2E41FFA3AFACC4DE52 A34C9D8A813D6A05FE7ECC05EB1D9 6B7F37
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DoWoo Digitech.Co.,Ltd	Vendor Artifact Hash:	
Address:	A-708, Ssangyong IT Twin-tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	SA IMD DW-IPC-A-10000	Optional Reservation Test:	Yes
HW Version:	DW-IPC-A-10000	Serial Number:	
SW Version:	Windows Server 2019 Standard\SN: DW 2301 IPCA1 001	Publisher Legacy Variants:	-
Key Words:	Measurement	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	04/11/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description Substation Automation Information Monitoring & diagnosis Device			

Files

23-014054-04-2_Dowoo_SA IMD_Server_Ed2_Certification_KTL.pdf 82.3 KB

04/11/2023

Herbert Falk