IEC TC57 WG10 Future Work - WG10 Future Work #6316

Clarification of using of ValKind, ValImport.

04/11/2023 08:42 AM - Vladan Cvejic

Status:	New	**Start date:**	11/24/2020
Priority:	Normal	**Due date:**	
Assignee:	Carlos Rodriguez del Castillo	**% Done:**	0%
Category:		**Estimated time:**	0.00 hour
Target version:			
Source:	RTE	**Standard(s):**	IEC 61850-6
TF Unique ID:	21 #RTE	**Needs More Information:**	No
WG10 Proposal:		**Assigned TF:**	61850-6
Discuss in Upcoming Meeting:	No	**Target edition:**	Next
Short Proposal:	valImport is being used today for exactly the opposite one, to prevent RTE provide more detailed information and we will take a look on it. ICT to accept modified values from outside tools.		

Description

Clarification of using of ValKind, ValImport.
Details: In order to do top-down engineering, we propose to add the possibility, in SCT, to modifiy ValImport from true to false, and that ValImport can't be modified by ICT after.
Arguments: The objective is to be able to manage engineering from the SCT.

Proposal descriptions

Create a new attribute to indicate when the ICT is forbidden to modify a specific data attribute.
Move the issue to FutureImprovement database.

Related issues:

Copied from IEC 61850 User Feedback Task Force - Support #624: Clarification ...	**Resolved**	**11/24/2020**	**11/24/2022**

History

#1 - 04/11/2023 08:42 AM - Vladan Cvejic

- Copied from Support #624: Clarification of using of ValKind, ValImport. added

#2 - 06/15/2023 11:59 AM - Joel Greene

- Target edition set to Edition 3

#3 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work

- Source deleted (RTE)

- TF Unique ID deleted (21 # RTE)

- Discuss in Upcoming Meeting deleted (No)

- Proposal descriptions updated

- Short Proposal deleted (valImport is being used today for exactly the opposite one, to prevent RTE provide more detailed information and we will take a look on itICT to accept modified values from outside tools.)

- Standard(s) deleted (IEC 61850-6)

- Needs More Information deleted (No)

#4 - 06/21/2023 02:01 AM - Vladan Cvejic

- Source set to RTE

- TF Unique ID set to 21 #RTE

- Discuss in Upcoming Meeting set to No

- Proposal descriptions updated

- Short Proposal set to valImport is being used today for exactly the opposite one, to prevent RTE provide more detailed information and we will take a look on it. ICT to accept modified values from outside tools.

- Standard(s) set to IEC 61850-6

- Needs More Information set to No

#5 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition changed from Edition 3 to Not assigned

#6 - 10/26/2023 04:58 AM - Vladan Cvejic

- Target edition changed from Not assigned to Next

- Assigned TF 61850-6 added