

IEC 61850 Certificate - IEC 61850 Certificate #6317

Siemens 7SL86

04/13/2023 07:26 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	CPRI-Siemens-CPRI BLRSGRL23TC0003.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: D43BA99663938679C99AB9842CA21165958E8412DC4C619D50392E563B4E46A7
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SIEMENS LTD	Vendor Artifact Hash:	
Address:	Verna Plot No - L6, Verna Industrial Estate, Opp. Goa - Mumbai highway, Verna, South Goa - 403722 INDIA	Umbrella Organization:	
Product:	Siemens 7SL86	Optional Reservation Test:	Yes
HW Version:	7SL86 with CP300\Serial No.: BM2212003344	Serial Number:	
SW Version:	V09.40	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	04/13/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
LINE PROTECTION Type I Model No.: 7SL86 (SIP 5) Product Code.: P1C547277			

Files

CPRI-Siemens-CPRI BLRSGRL23TC0003.pdf	980 KB	04/13/2023	Herbert Falk
---------------------------------------	--------	------------	--------------