

IEC TC57 WG10 Future Work - WG10 Future Work #6319

maxAttributes - conflicting requirements between GOOSE and reporting

04/18/2023 12:30 PM - IEC 61850 TPWG

Status:	New	Start date:	04/18/2023
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:			
Source:		Standard(s):	IEC 61850-6
TF Unique ID:		Needs More Information:	No
WG10 Proposal:		Assigned TF:	61850-6
Discuss in Upcoming Meeting:	No	Target edition:	Next
Short Proposal:			
Description			
Per discussion in TPWG, there is possibly a need to describe maxAttributes for GOOSE and reporting separately as (L2) GOOSE PDU size limit restricts here.			
Proposal descriptions			
To be investigated in part 6.			

History

#1 - 06/15/2023 11:59 AM - Joel Greene

- Target edition set to Edition 3

#2 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work

- Discuss in Upcoming Meeting deleted (No)

- Needs More Information deleted (No)

#3 - 06/21/2023 01:59 AM - Vladan Cvejic

- Discuss in Upcoming Meeting set to No

- Needs More Information set to No

#4 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition changed from Edition 3 to Not assigned

#5 - 10/26/2023 04:58 AM - Vladan Cvejic

- Proposal descriptions updated

- Standard(s) set to IEC 61850-6

- Target edition changed from Not assigned to Next

- Assigned TF 61850-6 added