

SCL Tooling - Issues #6324

sCnf6 - not all extRef require intAddr not referring to external device

04/26/2023 08:08 AM - Richard Schimmel

Status: Rejected	Due date: 05/16/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: sCnf6
61850 Standard:	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Amd1 ICT TP1.0	

Description

sCnf6 states: *Note: the intAddr should not contain external data.*

I agree with this note when ExtRefs are in the ICD file. These are the "later binding" kind of ExtRefs.

When an ICT tool completes a later binding ExtRef from the ICD and exports the IID is it allowed to remove not used later binding ExtRefs? it should keep the intAddr value.

When an SCT/ICT tool adds new ExtRef and exports the IID it is allowed to use intAddr containing external data!

Update the test procedure accordingly

History

#1 - 05/02/2023 08:53 AM - IEC 61850 TPWG

- Due date set to 05/16/2023

- Status changed from New to In Progress

- Assignee set to Richard Schimmel

Richard to review further.

#2 - 05/16/2023 08:44 AM - IEC 61850 TPWG

- Status changed from In Progress to Rejected

Disagree. No change.

SCT is allowed to change extRef.

intAddr are local issue.