

SCL Tooling - Issues #6325

PIXIT missing entries on tlie1 "when supported"

04/26/2023 08:13 AM - Richard Schimmel

Status: Resolved	Due date:
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: tlie1
61850 Standard:	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Amd1 ICT TP1.0	

Description

tlie1 mentions several times "when supported". I propose to add a PIXIT entry to specify if the feature is supported or not:

- remove a Logical node Y/N
- remove an optional data object Y/N
- add a new Logical Node Y/N
- add a new data object to an existing Logical node Y/N

History

#1 - 05/16/2023 08:04 AM - IEC 61850 TPWG

- Status changed from New to Resolved

- Assignee set to Richard Schimmel

Agree.