

## SCL Tooling - Issues #6326

### tlle1 - remove step 10-14 to undo previous changes

04/26/2023 08:17 AM - Richard Schimmel

<b>Status:</b> Resolved	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> tlle1
<b>61850 Standard:</b>	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Amd1 ICT TP1.0	

**Description**

Step 10-14 require to undo previous changes. This is significant work without adding value to the test. It's more testing if the engineer remembers all the changes he made. I propose to remove step 10-14:

- 10) **Undo the changes done in step 2-5**
- 11) Export IID file
- 12) Verify new IID file is SCL conformant
- 13) Verify new IID file content is substantially identical to that in step 1 except NamPlt.configRev
- 14) Perform online test

#### History

#1 - 05/16/2023 08:09 AM - IEC 61850 TPWG

- Status changed from New to Resolved

- Assignee set to Richard Schimmel

Agree.