

SCL Tooling - Issues #6327

tTf2 - export CID file only for Ed2.1?

04/26/2023 08:21 AM - Richard Schimmel

Status: Resolved	Due date:
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: tTf2
61850 Standard:	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Amd1 ICT TP1.0	
Description	
The test procedure does not specify which edition the CID file should have. If the ICT does support Ed1 shall we verify the Ed1 CID file as well? Is it mandatory? When the SICS I44 is Y, does this apply to all supported Editions? Is a subset allowed for CID?	

History

#1 - 05/16/2023 08:20 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel

One supported schema should be tested.