

# IEC 61850 Certificate - IEC 61850 Certificate #6336

## 6MD85 (SIP 5) - BAY CONTROLLER

05/12/2023 06:32 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRI-SIEMENS_ CPRIBLRSGRL23TC0004.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 104CD1B0FBCFAD57B2003BE98E6AA 3F06A0A3219B1D0FB49563F14F37CB E9670
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SIEMENS LTD.,	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Verna Plot No - L6, Verna Industrial Estate, Opp. Goa - Mumbai highway, Verna, South Goa - 403722 INDIA	<b>Umbrella Organization:</b>	
<b>Product:</b>	6MD85 (SIP 5)	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	6MD85 with CP300	<b>Serial Number:</b>	BM2212008388
<b>SW Version:</b>	V09.40	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Bay Controller	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/12/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		

**Description**

Files	Size	Date	Reviewer
CPRI-SIEMENS_CPRIBLRSGRL23TC0004.pdf	959 KB	05/12/2023	Herbert Falk