

IEC 61850 Certificate - IEC 61850 Certificate #6337

Siemens 7SS85

05/16/2023 02:26 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	CPRI-SIEMENS_CPRI BLRSGRL23TC0005_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 53A2386175D7F78173F18335B6DAF12 BB814B14130B351A3D76E20F40F1C1 EBA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SIEMENS LTD.,	Vendor Artifact Hash:	
Address:	Verna Plot No - L6, Verna Industrial Estate, Opp. Goa - Mumbai highway, Verna, South Goa - 403722 INDIA	Umbrella Organization:	
Product:	7SS85	Optional Reservation Test:	Yes
HW Version:	7SS85 with CP300	Serial Number:	BM2212008354
SW Version:	V09.40	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	05/16/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

BUSBAR PROTECTION

Files

CPRI-SIEMENS_CPRI BLRSGRL23TC0005_Certificate.pdf	964 KB	05/16/2023	Herbert Falk
---	--------	------------	--------------