

# IEC 61850 Certificate - IEC 61850 Certificate #6352

## PROTECTION IED VIPAM5000-KF PT

05/24/2023 12:16 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200217-R1_VitrzroEM_VIPAM5000-KF PT_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: FBD9894893F8DD82D72C48CA0B6DA 0067DD8FC19E0213389190CFBB649A 702E4
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	VITZRO EM Co, Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	VITZRO Bldg, 7, Neungdong-ro 25-gil, Gwangjin-gu, Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	VIPAM5000-KF PT	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	Hardware version: 1.	<b>Serial Number:</b>	
<b>SW Version:</b>	Software version: 1.0(Rev:10)/Firmware version: 97.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/24/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### Files

23TC200217-R1\_VitrzroEM\_VIPAM5000-KF PT\_Server\_Ed2\_KERI.pdf 25 KB

05/24/2023

Herbert Falk