

IEC 61850 Certificate - IEC 61850 Certificate #6353

IED T-IED 23kV

05/24/2023 12:29 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-029448-01-1_KMData_T-IED_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: ACC6DBA27AADDDD4CA8246FC215B FFD5DB98F0479CDB3F1360532EA3DF C93590
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	KMDATA INC.	Vendor Artifact Hash:	
Address:	505-2, Daeryung Techno Town 1-cha, Gasan Digital 2-ro 18, Geumcheon-gu, Seoul, Republic of Korea	Umbrella Organization:	
Product:	T-IED 23kV	Optional Reservation Test:	No
HW Version:	T-IED 23kV	Serial Number:	TIED23-60-2305002
SW Version:	Software Version 2.0.0/OS : GNU/Linux armv71 ver.4.1.18	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	05/24/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

History

#1 - 05/25/2023 06:29 AM - Herbert Falk

- IEC 61850 Blocks Certified deleted (Substitution (B3))

Files

23-029448-01-1_KMData_T-IED_Server_Ed2_Certification_KTL.pdf 116 KB 05/24/2023 Herbert Falk