

# IEC 61850 Certificate - IEC 61850 Certificate #6354

## IED T-IED 170kV

05/24/2023 12:34 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-029992-01-1_KMData_T-IED 170kV_Server_Ed2_Certification_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 742C06A2D04A8122B2D94BFE7D891E B6ECC18CC478E3E0C5AE32E0492A1 3DB50
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	KMDATA INC.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	505-2, Daeryung Techno Town 1-cha, Gasan Digital 2-ro 18, Geumcheon-gu, Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	T-IED 170kV	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	T-IED 170kV	<b>Serial Number:</b>	TIED170-60-2305001
<b>SW Version:</b>	Software Version 2.0.0/OS : GNU/Linux armv71 ver. 4.1.18	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/24/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			

### Files

23-029992-01-1_KMData_T-IED 170kV_Server_Ed2_Certification_KTL.pdf	947KB	05/24/2023	Herbert Falk
--	-------	------------	--------------