IEC 61850 Certificate - IEC 61850 Certificate #6361

APEX 150 P3E

05/31/2023 11:07 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	CPRI-SECURE METERS_CPRIBLRSGRL23TC0006_Certificate.pdf
61850 Tested Aspects:	Server	**Certificate Hash:**	SHA256: 29AA45C92E05D43A22D6F5CCAD4BAEEADF42C60B1964AA7F5C70F09FE167CECD
Company:	M/s. Secure Meters Limited	**Vendor Artifact File Name:**	
Address:	Udaipur, Rajasthan- 313003 INDIA	**Vendor Artifact Hash:**	
Product:	APEX 150 P3E	**Umbrella Organization:**	
HW Version:	003	**Optional Reservation Test:**	No
SW Version:	0.16	**Serial Number:**	RND2232
Key Words:		**Publisher Legacy Variants:**	-
Test Procedure Version:	2.0.6	**Publisher Preferred Rates:**	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Herbert Falk	**Subscriber Legacy Variants:**	-
Approval Date:	05/31/2023	**Subscriber Preferred Variants:**	
Standards Tested:	61850-8-1	**Subscriber Preferred Rates:**	-
Current Test Lab Name:	Central Power Research Institute India (A)	**Product Variants:**	
Test Document:	Edition 2 Server Test Procedures version 2.0.6		

Description

Files

CPRI-SECURE METERS_CPRIBLRSGRL23TC0006_Certificate.pdf	740 KB	05/31/2023	Herbert Falk