

IEC 61850 Certificate - IEC 61850 Certificate #6361

APEX 150 P3E

05/31/2023 11:07 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	CPRI-SECURE METERS_CPRI BLRSGRL23TC0006_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 29AA45C92E05D43A22D6F5CCAD4BA EEADF42C60B1964AA7F5C70F09FE16 7CECD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. Secure Meters Limited	Vendor Artifact Hash:	
Address:	Udaipur, Rajasthan- 313003 INDIA	Umbrella Organization:	
Product:	APEX 150 P3E	Optional Reservation Test:	No
HW Version:	003	Serial Number:	RND2232
SW Version:	0.16	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	05/31/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			

Files

CPRI-SECURE METERS_CPRI BLRSGRL23TC0006_Certificate.pdf 740 KB 05/31/2023 Herbert Falk