

IEC 61850 Certificate - IEC 61850 Certificate #6363

SA ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000

05/31/2023 11:22 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-014053-04-3_Dowoo_SA-ICD_Client_Ed2_Certificate_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 5BD946AAA13B7AD3B3F48584C22E72 9543DAB62BE62EF27ABC771B346320 7388
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	DoWoo Digitech. Co., Ltd	Vendor Artifact Hash:	
Address:	A-708, Ssangyong IT Twin-tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	SA ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	Optional Reservation Test:	Yes
HW Version:	DW-IPC	Serial Number:	DW 2301 IPCA2 001
SW Version:	1.0/Windows Server 2019 Standard	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	-
Approval Date:	05/31/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

History

#1 - 05/31/2023 11:27 AM - Herbert Falk

- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

Files

23-014053-04-3_Dowoo_SA-ICD_Client_Ed2_Certificate_KTL.pdf	113 KB	05/31/2023	Herbert Falk
--	--------	------------	--------------