

IEC 61850 Certificate - IEC 61850 Certificate #6364

SA-ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000

05/31/2023 11:27 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-014053-04-4_Dowoo_SA-ICD_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: C64CB7AF71C06DCFE637765D878746 256374C6EB839FA0AB54E4CD97AF7A A016
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DoWoo Digitech. Co., Ltd	Vendor Artifact Hash:	
Address:	A-708, Ssangyong IT Twin-tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	SA-ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	Optional Reservation Test:	No
HW Version:	DW-IPC	Serial Number:	DW 2301 IPCA2 001
SW Version:	1.0/ Windows Server 2019 Standard	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	05/31/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

Files

23-014053-04-4_Dowoo_SA-ICD_Server_Ed2_Certification_KTL.pdf 113 KB 05/31/2023 Herbert Falk