

## IEC 61850 User Feedback Task Force - Improvement #6370

### SBOs to be deprecated in future.

06/12/2023 06:50 AM - Vladan Cvejic

<b>Status:</b> Resolved	<b>Start date:</b> 06/12/2023
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Category:</b>	<b>% Done:</b> 0%
<b>Target version:</b>	<b>Estimated time:</b> 0.00 hour
<b>ID:</b>	<b>To discuss in WG10:</b> No
<b>Source:</b>	<b>Short Proposal:</b>
<b>TF Unique ID:</b>	<b>Standard(s):</b>
<b>WG10 Proposal:</b>	<b>Needs More Information:</b> No
<b>Estimated Completion:</b>	<b>Assigned TF:</b> None
<b>Discuss in Upcoming Meeting:</b> No	
<b>Description</b> It was decided on the WG10 plenary meeting in Regensburg (DE) to deprecate SBOs i.e. firstly we shall recommend not to be used and later to deprecate it (Edition 3). This issue is entered into UFTF in order to copy it later to Future Work.	
<b>Related issues:</b> Copied to IEC TC57 WG10 Future Work - WG10 Future Work #6410: SBOs to be dep... <b>New</b> <b>06/12/2023</b>	

#### History

##### #1 - 06/20/2023 09:38 AM - Vladan Cvejic

- Copied to WG10 Future Work #6410: SBOs to be deprecated in future. added

##### #2 - 06/20/2023 09:39 AM - Vladan Cvejic

- Status changed from New to Resolved

##### #3 - 06/20/2023 09:39 AM - Vladan Cvejic

- Discuss in Upcoming Meeting changed from Yes to No