

IEC 61850 Certificate - IEC 61850 Certificate #6373

Protection IED (K-IED V100)

06/12/2023 09:45 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200380_Kyongbo_IED_K-IED V100_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: A1F10A5EBCF39B57CB1E55D9C80101 5CE2260F18C95D0AFC482EED008922 B18C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Kyongbo Electric Co, Ltd	Vendor Artifact Hash:	
Address:	5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul, Republic of Korea	Umbrella Organization:	
Product:	Protection IED (K-IED V100)	Optional Reservation Test:	Yes
HW Version:	MCU version: 2.00/DSP version: 1.00	Serial Number:	
SW Version:	COMM version: 2.00	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	06/12/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			

Files

23TC200380_Kyongbo_IED_K-IED V100_Server_Ed2_KERI.pdf	505 KB	06/12/2023	Herbert Falk
---	--------	------------	--------------