

# IEC 61850 Certificate - IEC 61850 Certificate #6374

## Protection IED (K-IED BC100)

06/12/2023 09:58 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23TC200381_Kyongbo_IED_K-IED BC100_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	23TC200381_Kyongbo_IED_K-IED BC100_Server_Ed2_KERI.pdf
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Kyongbo Electric Co, Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	Protection IED (K-IED BC100)	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	MCU version: 2.00/DSP version: 1.00	<b>Serial Number:</b>	
<b>SW Version:</b>	COMM version: 2.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/12/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### Files

23TC200381_Kyongbo_IED_K-IED BC100_Server_Ed2_KERI.pdf	505 KB	06/12/2023	Herbert Falk
--	--------	------------	--------------