

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6375

XCBR LN new DO to describe withdrawable circuit breaker

06/14/2023 08:15 AM - Vladan Cvejic

Status:	In Progress	Start date:	12/17/2020
Priority:	Normal	Due date:	06/17/2021
Assignee:	Christoph Brunner	% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	IEC 61850-7-500, IEC 61850-90-25
Category:	New section	Related TISSUE:	
Description			
Need new DO in LN XCBR to describe withdrawable circuit breaker. The informations needed are : position disconnected, DJ disconnected, DJ plugged in, Dryer fault. A backup solution is to use LN XSWI. XSWI.Pos indicates whether the withdrawable circuit breaker is connected or disconnected. Needed for some PACS functions.			
Related issues:			
Copied from IEC 61850 User Feedback Task Force - Improvement #630: XCBR LN ne...		Resolved	12/17/2020 06/17/2021

History

#1 - 06/14/2023 08:15 AM - Vladan Cvejic

- Copied from Improvement #630: XCBR LN new DO to describe withdrawable circuit breaker added

#2 - 06/14/2023 08:27 AM - Keith Gray

- Status changed from New to In Progress

- Assignee set to Christoph Brunner

- Category changed from Not yet categorized to New section

#3 - 08/24/2023 07:57 AM - Keith Gray

- TF 7-5 Project document IEC 61850-7-500, IEC 61850-90-25 added