

## 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6382

### Clarification on the ctlModel 1/3

06/14/2023 08:18 AM - Vladan Cvejic

|  |                                 |
|--|---------------------------------|
| <b>Status:</b> New   | <b>Start date:</b> 09/20/2021   |
| <b>Priority:</b> Normal  | <b>Due date:</b> 01/20/2022     |
| <b>Assignee:</b>   | <b>% Done:</b> 0%               |
| <b>Category:</b>   |                                 |
| <b>Target version:</b>   |                                 |
| <b>Source:</b>   | <b>TF 7-5 Project document:</b> |
| <b>Category:</b> Not yet categorized   | <b>Related TISSUE:</b>          |
| <b>Description</b><br>What is the purpose of 'ctlModel' at X group level, Y group level respectively? Operator switchgear controls are managed by CSWI LN, so a Select to allow the operator to think twice before Operate is not needed on X group level. |                                 |
| <b>Related issues:</b><br>Copied from IEC 61850 User Feedback Task Force - Feature #5078: Clarification... <b>Resolved</b> <b>09/20/2021</b> <b>01/20/2022</b>   |                                 |

### History

#1 - 06/14/2023 08:18 AM - Vladan Cvejic

- Copied from Feature #5078: Clarification on the ctlModel 1/3 added