

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6384

New controllable DO in RREC to define the mode of the recloser of the circuit breaker

06/14/2023 08:19 AM - Vladan Cvejic

Status: New	Start date: 10/23/2020
Priority: Normal	Due date: 11/24/2020
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document:
Category: Not yet categorized	Related TISSUE:
Description Details: Need to have a new controlable DO (as "RecCycMod") to define the mode of the recloser of the circuit breaker, in LN RREC; and to add new value to enumeration LiveDeadModeKind Mode of recloser should be : live line dead bus, live bus dead line... RTE uses a mode live -line / live bus which is not present in the enumeration.	
Related issues: Copied from IEC 61850 User Feedback Task Force - Feature #621: New controllab... In Progress 10/23/2020 11/24/2020	

History

#1 - 06/14/2023 08:19 AM - Vladan Cvejic

- Copied from Feature #621: New controllable DO in RREC to define the mode of the recloser of the circuit breaker added