

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6388

Clarifications on the local/remote concept 2/8

06/14/2023 08:21 AM - Vladan Cvejic

Status: In Progress	Start date: 09/20/2021
Priority: Normal	Due date: 01/20/2022
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document:
Category: Not yet categorized	Related TISSUE:
Description Add a statement about the intention of the L/R concept. Specify whether the L/R concept is applicable for operator controls exclusively, not for switchgear controls in general. Assume LD/LLN0.Loc="false". Will a switchgear control by GAPC (orCat="automatic-bay") be executed?	
Related issues: Copied from IEC 61850 User Feedback Task Force - Feature #5082: Clarification... Resolved 09/20/2021 01/20/2022	

History

#1 - 06/14/2023 08:21 AM - Vladan Cvejic

- Copied from Feature #5082: Clarifications on the local/remote concept 2/8 added

#2 - 10/05/2023 08:55 AM - Keith Gray

- Status changed from New to In Progress