

## 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6389

### Clarifications on the local/remote concept 3/8

06/14/2023 08:21 AM - Vladan Cvejic

<b>Status:</b> In Progress	<b>Start date:</b> 09/20/2021
<b>Priority:</b> Normal	<b>Due date:</b> 03/20/2022
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	
<b>Target version:</b>	
<b>Source:</b>	<b>TF 7-5 Project document:</b>
<b>Category:</b> Not yet categorized	<b>Related TISSUE:</b>
<b>Description</b>	
Add a statement about the use of XCBR.Loc (and similar LN classes). Assume XCBR.Loc="true". Will protection trips and switchgear controls by GAPC be rejected?	
<b>Related issues:</b>	
Copied from IEC 61850 User Feedback Task Force - Feature #5083: Clarification...	<b>Resolved</b> <b>09/20/2021</b> <b>03/20/2022</b>

#### History

**#1 - 06/14/2023 08:21 AM - Vladan Cvejic**

- Copied from Feature #5083: Clarifications on the local/remote concept 3/8 added

**#2 - 10/05/2023 08:55 AM - Keith Gray**

- Status changed from New to In Progress