

## 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6390

### Clarifications on the local/remote concept 4/8

06/14/2023 08:21 AM - Vladan Cvejic

<b>Status:</b> In Progress	<b>Start date:</b> 09/20/2021
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	
<b>Target version:</b>	
<b>Source:</b>	<b>TF 7-5 Project document:</b>
<b>Category:</b> Not yet categorized	<b>Related TISSUE:</b>
<b>Description</b>	
Add a statement about the dependency of LD contained LN.LocSta from LD/LLN0.LocSta . Part 7-1 clause 6.4.2.1, Figure 14 states "for complete LD". Is the statement in the figure applicable for 'MtlLev' only or for both 'MtlLev' and 'LocSta'?	
<b>Related issues:</b>	
Copied from IEC 61850 User Feedback Task Force - Feature #5084: Clarification...	<b>Resolved</b> <b>09/20/2021</b>

#### History

**#1 - 06/14/2023 08:21 AM - Vladan Cvejic**

- Copied from Feature #5084: Clarifications on the local/remote concept 4/8 added

**#2 - 10/05/2023 08:55 AM - Keith Gray**

- Status changed from New to In Progress