

## 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6391

### Clarifications on the local/remote concept 5/8

06/14/2023 08:21 AM - Vladan Cvejic

<b>Status:</b> In Progress	<b>Start date:</b> 09/20/2021
<b>Priority:</b> Normal	<b>Due date:</b> 03/20/2022
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	
<b>Target version:</b>	
<b>Source:</b>	<b>TF 7-5 Project document:</b>
<b>Category:</b> Not yet categorized	<b>Related TISSUE:</b>
<b>Description</b> Add a statement about the dependency of 'LN.Loc' contained in LD from LD/LLN0.Loc (and LocSta, as applicable). Is this dependency limited to contained LN instances of that LD or, in the case of nested LD, including also subordinate levels? (see Tissue 1778)	
<b>Related issues:</b> Copied from IEC 61850 User Feedback Task Force - Feature #5085: Clarification... <b>Resolved</b> <b>09/20/2021</b> <b>03/20/2022</b>	

#### History

##### #1 - 06/14/2023 08:21 AM - Vladan Cvejic

- Copied from Feature #5085: Clarifications on the local/remote concept 5/8 added

##### #2 - 10/05/2023 08:55 AM - Keith Gray

- Status changed from New to In Progress