

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6392

Clarifications on the local/remote concept 6/8

06/14/2023 08:22 AM - Vladan Cvejic

Status: In Progress	Start date: 09/20/2021
Priority: Normal	Due date: 01/20/2022
Assignee:	% Done: 0%
Category:	
Target version:	
Source:	TF 7-5 Project document:
Category: Not yet categorized	Related TISSUE:
Description Add a statement in the description text of 'SwModKey' that this setting effects all contained CSWI LN instances of that LD. Is the dependency of 'SwModKey' limited to contained CSWI LN instances of that LD or, in the case of nested LD, including also subordinate levels?	
Related issues: Copied from IEC 61850 User Feedback Task Force - Feature #5086: Clarification... Resolved 09/20/2021 01/20/2022	

History

#1 - 06/14/2023 08:22 AM - Vladan Cvejic

- Copied from Feature #5086: Clarifications on the local/remote concept 6/8 added

#2 - 10/05/2023 08:55 AM - Keith Gray

- Status changed from New to In Progress