

61850-7-5 and 61850-7-500 - IEC61850-7-5 #6394

Clarifications on the local/remote concept 8/8

06/14/2023 08:23 AM - Vladan Cvejic

Status:	In Progress	Start date:	09/20/2021
Priority:	Normal	Due date:	01/20/2022
Assignee:		% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	IEC 61850-7-5
Category:	Not yet categorized	Related TISSUE:	
Description			
Annex B, Table B.1 states that "Manual Control at switch (process)" was always allowed. Isn't it the status of a control switch modelled as XCBR.LockKey="true" which releases the manual control at the switchgear? As long as this control switch is not activated, manual control is not possible. To prevent from switchgear controls other than local during this time, as long as XCBR.LockKey="true", no control issued by the IED is accepted.			
Related issues:			
Copied from IEC 61850 User Feedback Task Force - Feature #5088: Clarification...		Resolved	09/20/2021 01/20/2022

History

#1 - 06/14/2023 08:23 AM - Vladan Cvejic

- Copied from Feature #5088: Clarifications on the local/remote concept 8/8 added

#2 - 09/14/2023 08:04 AM - Keith Gray

- Status changed from New to In Progress

- TF 7-5 Project document IEC 61850-7-5 added