

Server - Issues #6453

sSvs8 the minimum svID length 4chars is not right against test case sSvp14

06/28/2023 03:30 PM - Hua Qin

Status: Closed	Due date: 07/25/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: TP1.3
Clause Reference:	Test Case ID: sSvs8
61850 Standard: 9-2	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: ED2.1 TP1.2	

Description

Test case sSvs8 tests the maximum and minimum svID length. For the minimum svID length, it specifies 4 chars. The minimum should be 1 char.

This is updated in test case sSvp14 (from 4 chars to 1 char)

Suggest to update the abstract test description and detailed test case from 4 chars to 1 char.

History

#1 - 07/11/2023 08:56 AM - IEC 61850 TPWG

- Due date set to 07/25/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

#2 - 07/19/2023 03:25 AM - Richard Schimmel

- File Solution to redmine 6453 sSvs8.docx added
- 61850 Standard 9-2 added

Attached the solution as proposed.

#3 - 07/25/2023 08:09 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

#4 - 03/01/2024 10:04 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3

Files

Solution to redmine 6453 sSvs8.docx	23.8 KB	07/19/2023	Richard Schimmel
-------------------------------------	---------	------------	------------------