

CIM Issues - CIM Issues #6454

RemoteUnit minor typo in 301 description

06/28/2023 04:27 PM - Yang Feng

Status: New	
Priority: Normal	
Target version:	
Solution Version:	Sub-Clause:
CIM Impacted Groups: WG13	Paragraph:
Requestor: Yang Feng	Table:
Standard(s): 61970-301	Origination Date: 06/28/2023
Version:	Origination ID:
Clause:	Originally Assigned To:
Description	
The following paragraph is included as part of the UML description (301) of RemoteUnit: "The communication with the remote unit can be through various standard protocols (e.g. IEC 61870, IEC 61850) or non standard protocols (e.g. DNP, RP570, etc.)"	
I believe it should be IEC 60870 (IEC 104) instead of 61870.	