

Client - Issues #6463

cSrv7, cSvrN3 some clients only read DA (not DO)

07/03/2023 04:35 AM - Richard Schimmel

Status: Resolved	Due date: 07/25/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: Yes	Updated Test Document:
Clause Reference:	Test Case ID: cSrv7, cSrvN3
61850 Standard: 7-2	Closed Reason: Test Procedure Update
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Ed2 and Ed2Amd1	

Description

These test cases require to test both reading a DA and a DO. Some clients only read a DA. As such we can't test the DO steps. I propose to add "when supported" to the DO steps.

History

#1 - 07/11/2023 08:42 AM - IEC 61850 TPWG

- Subject changed from cSrv7, sSvrN3 some clients only read DA (not DO) to cSrv7, cSvrN3 some clients only read DA (not DO)
- Due date set to 07/25/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

Accepted. Richard to modify TP "when supported" to allow device that supports only DA or DO.

#2 - 07/19/2023 06:47 AM - Richard Schimmel

- File Solution to redmine 6463 cSrv7 and cSrvN3.docx added
- Test Case ID set to cSrv7, cSrvN3

Attached the solution. Either DA or DO is allowed.

#3 - 07/25/2023 08:07 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

Files

Solution to redmine 6463 cSrv7 and cSrvN3.docx	22.4 KB	07/19/2023	Richard Schimmel
--	---------	------------	------------------