

# IEC 61850 Certificate - IEC 61850 Certificate #6467

## MRD-HB (101PYA) Biased differential relay

07/10/2023 03:38 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-2876_DNV_Mitsubishi_MRD_HB_ServerEd2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 218179D96827A17120A13EEE9CD67C 8983DD065FC4C0CD750BA94D40B031 0E90
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Mitsubishi Electric Corporation	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	<b>Umbrella Organization:</b>	
<b>Product:</b>	MRD-HB (101PYA) Biased differential relay	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	219611-52901
<b>SW Version:</b>	IEC 61850 version: 2.0.0.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/10/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### Files

23-2876_DNV_Mitsubishi_MRD_HB_ServerEd2_Certificate.pdf	122 KB	07/10/2023	Herbert Falk
---	--------	------------	--------------