

## Server - Issues #6469

### Type and size of Length field value (TLV) encoding in SV

07/11/2023 07:58 AM - IEC 61850 TPWG

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b>	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> TP1.3
<b>Clause Reference:</b>	<b>Test Case ID:</b> sSvp7
<b>61850 Standard:</b>	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b> <a href="https://iec61850.tissue-db.com/tissue/1720">https://iec61850.tissue-db.com/tissue/1720</a>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b>	
<b>Description</b>	

#### History

##### #1 - 07/25/2023 08:00 AM - Richard Schimmel

- Status changed from New to In Progress
- Test Case ID set to sSvp7

Test case sSvp7 already states the encoding shall use the minimum length TLV encoding.

##### #2 - 07/25/2023 08:14 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

##### #3 - 03/01/2024 10:05 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3