

Server - Issues #6470

SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692)

07/11/2023 07:58 AM - IEC 61850 TPWG

Status: Closed	Due date: 08/08/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: TP1.3
Clause Reference:	Test Case ID: sSvp15
61850 Standard: 9-2	Closed Reason: --Not Set--
Triggering Tissue: https://iec61850.tissue-db.com/tissue/1692	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Amd1 TP1.2	
Description	

History

#1 - 07/25/2023 08:19 AM - IEC 61850 TPWG

- Due date set to 08/08/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Mandatory for publisher if PTP supported, including configuration ability to not send for backwards compatibility.

Subscriber must accept messages with or without.

#2 - 07/26/2023 04:50 AM - Richard Schimmel

- Subject changed from SynchSrcID support mandatory for devices that support IEC 61850-9-3 to SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692)
- Initial Test Document set to Amd1 TP1.2
- Test Case ID set to sSvp15
- 61850 Standard 9-2 added

Table A.4.2 specifies that if PTP is supported test case sSvp9 and sSvp15 are applicable.
sSvp15 = "Verify synchSourceId matches the GMC ID". So the tissue is already processed in the conformance test.

#3 - 08/08/2023 08:41 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

#4 - 03/01/2024 10:05 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3