

Client - Issues #6471

Select.response+ (Tissue 1753)

07/11/2023 07:59 AM - IEC 61850 TPWG

Status: Resolved	Due date: 08/22/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: cSBOs10
61850 Standard: 8-1	Closed Reason: --Not Set--
Triggering Tissue: https://iec61850.tissue-db.com/tissue/1753	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Client Amd1 TP1.0	
Description	

History

#1 - 07/25/2023 08:22 AM - IEC 61850 TPWG

- Project changed from Server to Client
- Due date set to 08/08/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

#2 - 08/08/2023 08:39 AM - IEC 61850 TPWG

- Due date changed from 08/08/2023 to 08/22/2023

#3 - 08/21/2023 09:56 AM - Richard Schimmel

- File Solution to redmine 6471 Select Response.docx added
- Subject changed from Select.response+ to Select.response+ (Tissue 1753)
- Initial Test Document set to Client Amd1 TP1.0
- Test Case ID set to cSBOs10
- 61850 Standard 8-1 added

The tissue specifies:

Client implementation conformant to this standard shall accept for backward compatibility reason **ANY non-null** value in particular
[CO_CtrlObjectRef]\$Oper
[CO_CtrlObjectRef]\$SBO

Richard:

- Part 8-1 Ed1 §20.4.2 states: the Select Response+ is a non-NULL value for the SBO attribute.
- Part 8-1 Ed2.1 §20.5.4 states: the Select Response+ is a non-NULL value for the SBO attribute. But table 96 states <CO_CtrlObjectRef>

Update sSBOs10 to use: any value not matching <CO_CtrlObjectRef> for example with tailing \$SBO/\$Oper

#4 - 08/22/2023 08:10 AM - Joel Greene

- Status changed from In Progress to Resolved

Accepted

Files

Solution to redmine 6471 Select Response.docx

17.7 KB

08/21/2023

Richard Schimmel