

# IEC 61850 Certificate - IEC 61850 Certificate #6475

## SAM600 Process Interface Unit

07/11/2023 11:15 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-2845_DNV_Hitachi_SAM600_ServerEd2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 609A6DF5639148D369C444D04490E68 71375447E08E3F192E1D6785B1D3BF2 49
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Hitachi Energy Sweden AB	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	GA Products S-721 59 Västerås Sweden	<b>Umbrella Organization:</b>	
<b>Product:</b>	SAM600 Process Interface Unit	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	Product version: 3.0.0	<b>Serial Number:</b>	T2250255
<b>SW Version:</b>	:0.4.73.175	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/11/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### Files

23-2845_DNV_Hitachi_SAM600_ServerEd2_Certificate.pdf	122 KB	07/11/2023	Herbert Falk
--	--------	------------	--------------