

IEC 61850 Certificate - IEC 61850 Certificate #6478

FTU-R200i

07/19/2023 07:07 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-039257-01-1_PNCTech_FTU-R200i_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 216C2BAA0EB263745E739E2AE0B970 17EFE44B92227FFEA2E64453A49FEB 2F2B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, 14042, Republic of Korea	Umbrella Organization:	
Product:	FTU-R200i	Optional Reservation Test:	Yes
HW Version:	FTU-R200i	Serial Number:	FTU-R200i-2306-0001
SW Version:	6.0.2/OS : SYS/BIOS 6.42.1.20 (Ti)	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/19/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

History

#1 - 07/19/2023 07:08 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

Files

23-039257-01-1_PNCTech_FTU-R200i_Server_Ed2_Certification_KTL.pdf 159 KB

07/19/2023

Herbert Falk