

IEC 61850 Certificate - IEC 61850 Certificate #6479

SA IMD DAONSY MSA-SMD-ED2

07/19/2023 07:13 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-039476-05-1_DAONSY DAONSY MSA-SMD-ED2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: AF27DE0FA35647ED99B8B7F21F1316 5F98B08726E775D1CEAEAA5F524E5B EC8B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DAONSY Co., Ltd.	Vendor Artifact Hash:	
Address:	70, Aenggogae-ro 556beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692	Umbrella Organization:	
Product:	SA IMD DAONSY MSA-SMD-ED2	Optional Reservation Test:	No
HW Version:	DAONSY MSA-SMD-ED2	Serial Number:	DO-MSA-SMD-ED2-00001
SW Version:	Windows Server 2019	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/19/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description (Substation Automation Information Monitoring & diagnosis Device)			

History

#1 - 07/19/2023 08:55 PM - Herbert Falk

- IEC 61850 Blocks Certified Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5) added

Files

23-039476-05-1_DAONSY DAONSY MSA-SMD-ED2_Certification_KTL.pdf 07/19/2023 Herbert Falk