

IEC 61850 Certificate - IEC 61850 Certificate #6480

SA IMD YSSMD-7300

07/19/2023 07:21 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-039351-04-1_YouSung_YSSMD-7300_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: EA3546F192978167B66B996870AE863 B0800D3ACF60D5CEDA5AB55F9A21B 6736
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YouSung Instrument & Electric Co.,Ltd.	Vendor Artifact Hash:	
Address:	37, Namdongdong-ro 64beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692	Umbrella Organization:	
Product:	SA IMD YSSMD-7300	Optional Reservation Test:	Yes
HW Version:	YSSMD-7300	Serial Number:	
SW Version:	1.0/Windows Server 2019	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/19/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

(Substation Automation Information Monitoring & diagnosis Device)

History

#1 - 07/19/2023 07:22 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

Files

23-039351-04-1_YouSung_YSSMD-7300_Server_Ed2_Certification_KTL.pdf

07/19/2023

Herbert Falk