

IEC 61850 Certificate - IEC 61850 Certificate #6481

AXC F 3152

07/19/2023 07:30 AM - Herbert Falk

Status:	Approved	Test Document:	AXC F 3152
Priority:	Normal	Certificate Name:	23-2946_DNV_PHOENIX CONTACT_AXC F 3152_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: B6696021A13549E31D345F5F599CF1E 1D45C37F998BE05C18FA19BF883BD9 DB9
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Phoenix Contact S.p.A.	Vendor Artifact Hash:	
Address:	Via Bellini 39/41 20095 Cusano Milanino Italy	Umbrella Organization:	
Product:	AXC F 3152	Optional Reservation Test:	Yes
HW Version:	1.0	Serial Number:	1368219808
SW Version:	02	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/19/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Central plant controller			

History

#1 - 07/19/2023 07:30 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

Files

23-2946_DNV_PHOENIX CONTACT_AXC F 3152_ServerEd2_Certificate.pdf	07/19/2023	Herbert Falk
--	------------	--------------