

# IEC 61850 Certificate - IEC 61850 Certificate #6485

## ECU-4784

07/26/2023 10:25 AM - Herbert Falk

<b>Status:</b>	Approved		
<b>Priority:</b>	Normal		
<b>61850 Edition:</b>	Edition 2	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>61850 Tested Aspects:</b>	Server	<b>Certificate Name:</b>	23-039352-02-1_YouSung_ECU-4784_Server_Ed2_Certification_KTL.pdf
<b>Company:</b>	YouSung Instrument & Electric Co., Ltd	<b>Certificate Hash:</b>	SHA256: 1A3BE5DB2369D412BC161FCD6401D C182DE909BF7605CC5AE69DD83A04 07C453
<b>Address:</b>	37, Namdongdong-ro 64beon-gil, Namdong-gu, Incheon, Republic of Korea, 21692	<b>Vendor Artifact File Name:</b>	
<b>Product:</b>	ECU-4784	<b>Vendor Artifact Hash:</b>	
<b>HW Version:</b>	2.0/OS : Windows Server 2019	<b>Umbrella Organization:</b>	
<b>SW Version:</b>	ECU-4784	<b>Optional Reservation Test:</b>	Yes
<b>Key Words:</b>		<b>Serial Number:</b>	KMA7946297
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Publisher Preferred Rates:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Publisher Preferred Variants:</b>	
<b>Approval Date:</b>	07/26/2023	<b>Subscriber Legacy Variants:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Subscriber Preferred Variants:</b>	
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)	<b>Subscriber Preferred Rates:</b>	-
<b>Description</b>			
SA LID (Substation Automation Local Information processing Device)			

### Files

23-039352-02-1\_YouSung\_ECU-4784\_Server\_Ed2\_Certification\_KTL.pdf 7 KB

07/26/2023

Herbert Falk