

IEC 61850 Certificate - IEC 61850 Certificate #6487

Protection IED (SUF-K110)

07/26/2023 10:56 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23TC200525_Sanion_IED_SUF-K110_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 02A20DD2D163CFBD67C04C040D2FD 01AA0AEFB9E9732CC4FF8095D614B9 5C730
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co, Ltd	Vendor Artifact Hash:	
Address:	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	Umbrella Organization:	
Product:	Protection IED (SUF-K110)	Optional Reservation Test:	Yes
HW Version:	MPU version: 2.00/DSP version: 2.00	Serial Number:	
SW Version:	IEC 61850 version: 2.00	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/26/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			

Files

23TC200525_Sanion_IED_SUF-K110_Server_Ed2_KERI.pdf	507 KB	07/26/2023	Herbert Falk
--	--------	------------	--------------