

Server - Issues #6491

Incorrect reference

07/28/2023 10:30 AM - Michael Haecker

Status:	Closed	Due date:	08/22/2023
Priority:	Low		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	TP1.3
Clause Reference:	sGos20, sGos21 and sGos22	Test Case ID:	
61850 Standard:	7-2	Closed Reason:	--Not Set--
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:			
Description			
In test procedures sGos20, sGos21 and sGos22 reference is made to "IEC 61850-7-2 Subclause 18.3.2.2". This subclause does not exist. Modify the reference to "IEC 61850-7-2 Subclause 18.2.3".			

History

#1 - 08/08/2023 08:53 AM - IEC 61850 TPWG

- Due date set to 08/22/2023
- Status changed from New to Resolved

Accepted.

#2 - 03/01/2024 10:06 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3