

IEC 61850 Certificate - IEC 61850 Certificate #6493

WAGO 750-8212/0040-0001

07/28/2023 12:31 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Conformance Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-2965_DNV_WAGO_750-8212_ClientEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: CBC64986DA2C5D8C4F3D45553E5425 1C3AF00B20693EF71FA70362A23C62 B99D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	WAGO GmbH & Co. KG	Vendor Artifact Hash:	
Address:	Hansastraße 27 32423 Minden Germany	Umbrella Organization:	
Product:	WAGO 750-8212/0040-0001	Optional Reservation Test:	No
HW Version:		Serial Number:	37SUN31564010260494977 0000000000005630
SW Version:	1.4.2.1	Publisher Legacy Variants:	-
Key Words:	RTU	Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	07/28/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

23-2965_DNV_WAGO_750-8212_ClientEd2_Certificate.pdf	120 KB	07/28/2023	Herbert Falk
---	--------	------------	--------------